



U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 164.112/108/0

Expires: 14 September 2011

INTERIOR FINISH (IMO)

CLAD-REX, INC.
11500 W. King Street
Franklin Park IL 60131

"Sea-Clad" plastic laminate interior finish approved as meeting Parts 2 and 5 of Annex 1 of the IMO FTP Code, in maximum thickness of 0.015 inches (0.38 mm).

Identifying Data: UL Report Project 06CA32881, File R25266, dated August 31, 2006, and USCG letter dated September 14, 2006.

Follow-up: UL

To be applied with Clad-Rex adhesive 8808.000 in accordance with manufacturer's instructions (1 mil typical wet film thickness with an adhesive application rate between 0.45 to 0.55 grams/sq. ft.).

Factory location: Franklin Park, IL

Approval valid only for products from above factory location



1408/06

The manufacturer is allowed to affix the Mark of Conformity according to Article 11 in the Council Directive 96/98/EC on Marine Equipment and issue a Declaration of Conformity as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment" signed February 2004 and by the "Agreement between the European Free Trade Association countries which are part of the European Economic Area and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment" signed October 2005. Item complies with requirements of Annex A.1, Item No. A.1/3.18 of the directive.

*** END ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 14th DAY OF
SEPTEMBER 2006, AT WASHINGTON D.C.


K. J. HEINZ
Acting Chief, Lifesaving and Fire Safety Standards Division
BY DIRECTION OF THE COMMANDANT